


NOTE:

1. CONCRETE STRADDLE BLOCKS FOR 12" AND LARGER WATER MAINS SHALL BE DESIGNED AND STAMPED BY THE PROJECT ENGINEER OF RECORD. PROVIDE CALCULATIONS FOR REVIEW AND APPROVAL.
2. USE 2" OFFSET OR MANUFACTURER RECOMMENDATION FOR MID-SPAN RESTRAINT.
3. TIE REBAR TO ITSELF TO HOLD FORM.
4. WRAP RESTRAINTS WITH 1 LAYER OF V-BIO® POLYETHYLENE ENCASEMENT PRIOR TO POURING CONCRETE. EXTEND PE WRAP A MINIMUM OF 6" BEYOND RESTRAINTS. SECURE TO PIPE WITH 10 MIL PVC PIPE WRAP TAPE.

Tualatin Valley Water District

 1850 SW 170th Ave. Beaverton, OR 97003
 (503) 848-3000 www.tvwd.org

DESIGNED: KLS

APPROVED: NWA

SCALE: NONE

STRADDLE BLOCK

DATE: 3/1/2018

DETAIL

304