



KEYNOTES:

- A. NORMALLY CLOSED VALVE
 - A.1 VALVE SIZE SHALL MATCH MAINLINE SIZE
 - A.2. ALL JOINTS SHALL BE RESTRAINED
 - A.3. SEE DETAIL 402 FOR VALVE BOX REQUIREMENTS
- B. LINE-SIZE X 2" THREADED TEE
- C. 2" BLOWOFF ASSEMBLY; SEE DETAIL 306
- D. MOVE TO OPPOSITE SIDE IF 12" MIN. IS NOT MAINTAINED
- E. 2"x6" BRASS NIPPLE

ALTERNATIVE METHOD:

- F. LINE-SIZE X 4" MJ TEE
- G. 4" MJ PLUG WITH OFFSET 2" TAP AT BOTTOM

Tualatin Valley Water District

1850 SW 170th Ave. Beaverton, OR 97003
 (503) 848-3000 www.tvwd.org

DESIGNED: KLS

APPROVED: NWA

SCALE: NONE

**2" BLOWOFF ASSEMBLY
 AT NORMALLY CLOSED
 PRESSURE ZONE BREAK**

DATE: 3/1/2018

DETAIL
305