



NOTES:

1. TRACING WIRE TO BE SINGLE CONTINUOUS LENGTH OF WIRE BETWEEN LOCATE STATIONS. IF SPLICE IS NEEDED, USE TS-19-IL OR MANUFACTURERS RECOMMENDED CONNECTORS.
2. PROVIDE CONCRETE PAD AROUND VALVE BOX IF LOCATED OUTSIDE OF PAVED AREAS. PER TVWD DETAIL 402.
3. INSTALLATION OF CONDUIT UNDER CURB AND SIDEWALK SHALL UTILIZE TRENCHLESS METHOD TO AVOID DAMAGE TO SIDEWALK

Tualatin Valley Water District

1850 SW 170th Ave. Beaverton, OR 97003
(503) 848-3000 www.tvwd.org

DESIGNED: KLS

APPROVED: NWA

SCALE: NONE

TRACER WIRE DETAIL

DATE: 3/1/2018

DETAIL

308